



- NOTES:**
- 1: Service point to be located by JEC personnel in all cases.
  - 2: Temp pole is to be located no more than a maximum of 20ft from a pole with service.
  - 3: All wiring shall be inspected prior to connection by JEC.
  - 4: All owner wiring practices are to be in accordance with the National Electrical Code, local, and or JEC specifications.

Local Inspectors

- |                         |                          |
|-------------------------|--------------------------|
| Burke: 706-554-8758     | Johnson: 478-484-8978    |
| Columbia: 706-868-3420  | McDuffie: 706-595-5355   |
| Emanuel: 478-237-6514   | Richmond: 706-312-5050   |
| Glascok: 706-598-2811   | Warren: 706-465-0310     |
| Jefferson: 478-625-4032 | Washington: 912-552-2937 |
| Jenkins: 478-982-2563   |                          |

|   |   |                    |               |
|---|---|--------------------|---------------|
| <b>JEFFERSON<br/>ENERGY<br/>COOPERATIVE</b> | <b>TEMPORARY METER POLE INSTALLATION<br/>TREATED, 25' CLASS 6 OR EQUAL BY OWNER</b> |                    |               |
|   | REVISED   | SCALE: 1" = 2.5ft. | ASSEMBLY      |
|   | 04/20/22  |                    | <b>OH-TMP</b> |