



Local Inspectors

- Burke: 706-554-8758
- Columbia: 706-868-3420
- Emanuel: 478-237-6514
- Glascok: 706-598-2811
- Jefferson: 478-625-4032
- Jenkins: 478-982-2563
- Johnson: 478-484-8978
- McDuffie: 706-595-5355
- Richmond: 706-312-5050
- Warren: 706-465-0310
- Washington: 912-552-2937

If mounting service equipment to Mobile Home, check with local inspector for approval.

NOTES:

- 1: Service point to be located by JEC personnel **in all cases.**
- 2: All wiring shall be inspected prior to connection by JEC.
- 3: All owner wiring practices are to be in accordance with the National Electrical Code, local, and or JEC specifications.
- 4: All 320A meter bases must have a lever by-pass.

JEFFERSON ENERGY COOPERATIVE	RESIDENTIAL OVERHEAD METER BASE		ASSEMBLY
	REVISED 04/20/22	SCALE: 1" = 2.5ft.	OH-MB