


Local Inspectors


Burke: 706-554-8758
 Columbia: 706-868-3420
 Emanuel: 478-237-6514
 Glascock: 706-598-2811
 Jefferson: 478-625-4032
 Jenkins: 478-982-2563
 Johnson: 478-484-8978
 McDuffie: 706-595-5355
 Richmond: 706-312-5050
 Warren: 706-465-0310
 Washington: 912-552-2937



NOTE:

JEC enters left-hand side
 of Urd meter base only!
 Suitable disconnect furnished
 by owner, is to be located
 on the right-hand side of
 the meter base only!

Rigid PVC
 Conduit 2 1/2"



Notes:

- 1: Service point to be located by JEC personnel in all cases.
- 2: Depth of trench shall be inspected prior to cable installation.
- 3: Failure to meet proper depths or service point locations can prolong service hookup.
- 4: All wiring shall be in accordance with the National Electrical Code, local, and or JEC specifications.
- 5: Conduit to extend outside any concrete areas. (Driveways & footings)

**JEFFERSON
 ENERGY
 COOPERATIVE**

TEMPORARY URD METER INSTALLATION

REVISED
 04/20/22

SCALE: 1" = 2.5ft.

ASSEMBLY
UG-TMP