



- NOTES:**
- 1: Service point to be located by JEC personnel in all cases.
 - 2: Temp pole is to be located no more than a maximum of 20ft from a pole with service.
 - 3: All wiring shall be inspected prior to connection by JEC.
 - 4: All owner wiring practices are to be in accordance with the National Electrical Code, local, and or JEC specifications.

Local Inspectors

- | | |
|-------------------------|--------------------------|
| Burke: 706-554-8758 | Johnson: 478-484-8978 |
| Columbia: 706-868-3420 | McDuffie: 706-595-5355 |
| Emanuel: 478-237-6514 | Richmond: 706-312-5050 |
| Glascok: 706-598-2811 | Warren: 706-465-0310 |
| Jefferson: 478-625-4032 | Washington: 912-552-2937 |
| Jenkins: 478-982-2563 | |

JEFFERSON ENERGY COOPERATIVE	TEMPORARY METER POLE INSTALLATION TREATED, 25' CLASS 6 OR EQUAL BY OWNER		
	REVISED	SCALE: 1" = 2.5ft.	ASSEMBLY
	04/20/22		OH-TMP